

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3774-1457:101 Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** DynaLock Corp., 705 Emmett Street, Forestville, CT 06011-9470  
Contact: \*Glen Girard (860) 582-4761 FAX (860) 585-0338

**DESIGN:** Model 3000 Series electromagnetic locking device. Unit is a direct-hold lock intended to be mounted for direct pull force. Upon loss of power, the unit is unlocked and the door is free to swing open. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 12 V AC/DC or 24 V AC/DC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction. Intended to be mounted in a horizontal position and to the underside of the header of the door frame on the stop side of the door.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as locking device for fire-rated and non fire-rated doors. Authority having jurisdiction shall be consulted prior to installation.

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**